



**Public Health**  
Environmental Health Services

**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

FACILITY NAME <b>HAMPTON INN &amp; SUITES</b>		DATE <b>4/14/2015</b>	REINSPECTION DATE <b>Not Specified</b>	PERMIT EXPIRATION <b>4/30/2015</b>
LOCATION <b>250 N 9TH ST, COLTON, CA 92324</b>			INSPECTOR <b>John Babalola</b>	
MAILING ADDRESS <b>105 DECKER CT STE 500, IRVING TX 75062</b>			IDENTIFIER: Pool	
TIME IN <b>2:09 PM</b>			SERVICE: 001 - INSPECTION - ROUTINE	
TIME OUT <b>3:05 PM</b>			RESULT: 05 - CORRECTIVE ACTION / FOLLOW UP REQ	
FACILITY ID <b>FA0008659</b>			ACTION: 13 - PERMIT SUSPENDED / FACILITY CLOSED	
RELATED ID <b>PR0014087</b>			PE <b>3620</b>	




**RECREATIONAL HEALTH - Public Pool - Initial Pool at Facility**

Based on an inspection this day, the items marked below identify the violation(s) in operation or facilities which must be corrected. The Permittee has the right to a hearing if requested in writing within 15 calendar days of receipt of this notice, to show cause why the permit to operate should not be suspended or revoked.

**86**  
SCORE

Failure to correct listed violation(s) prior to the designated compliance date may necessitate an additional reinspection at a charge of \$61.25 per 15 minutes with a minimum time of 30 minutes, and a minimum charge of \$122.50.

Ideal
In Compliance
Not in Compliance



temperature (°F)	No Data
observed flow (gpm)	No Data
required flow (gpm)	40
volume (gal)	No Data
area (sq ft)	No Data
occupancy	20

**36K402 Water Quality - Critical - Lack of Disinfectant** ⚠️ CRITICAL ⚠️

<b>POINTS</b> <b>4</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Provide at least 1.0 ppm of free chlorine in the pool. The chlorine level is observed at 0.0 ppm (zero) at the time of inspection.  Note: The pool is hereby ordered closed until the free chlorine level is adjusted. Call (800) 442-2283 for a re-inspection when the correction is made
	Not In Compliance	
	Violation Reference - CCR - 65529	

**Violation Description:** For pools using hypochlorite or gaseous chlorine without a stabilizer, a free chlorine residual at least 1.0 ppm shall be maintained throughout the pool. If cyanuric acid or a chlorinated isocyanurate is used, a free chlorine residual of at least 1.5 ppm shall be maintained throughout the pool.

**36K427 Safety - Safety Signs**

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Provide the phone number for the nearest emergency services and the name and address of the facility at the pool side. None observed.
	Not In Compliance	
	Violation Reference - CCR 24 - 3120B	

**Violation Description:** All signs shall have clearly legible letters or numbers not less than 4 inches high, unless otherwise required, affixed to a wall, pole, gate or similar permanent structure in a location visible to all pool users. The following shall be posted:

- Maximum number of pool users permitted for each pool.
- "NO DIVING" at pools with a maximum water depth of 6 feet or less.
- Where no lifeguard service is provided, a warning sign shall be posted stating, "WARNING: NO LIFEGUARD ON DUTY." The sign also shall state in letters at least 1 inch high, "Children under the age of 14 shall not use pool without a parent or adult guardian in attendance."
- An illustrated diagram with text at least 1/4 inch high of artificial respiration and CPR procedures.
- The emergency telephone number 911 with numbers not less than 4 inches (102mm), the number of the nearest emergency services and the name and street address of the pool facility with numbers and text not less than 1 inch (25 mm) shall be posted.
- A warning sign for spa pools with "CAUTION" language.
- Where pools were constructed for which lighting was not required, a sign shall be posted at each pool entrance on the outside of the gate(s) stating, "NO USE OF POOL ALLOWED AFTER DARK."
- A sign shall be posted on the exterior side of gates and doors leading into the pool enclosure area stating, "KEEP GATE CLOSED" or "KEEP DOOR CLOSED".
- A sign in letters at least 1 inch high and in a language or diagram that is clearly stated shall be posted at the entrance area of a public pool which states that persons having currently active diarrhea or who have had active diarrhea within the previous 14 days shall not be allowed to enter the pool water.
- A sign in letters at least 1 inch high shall be posted that describes the requirements for wave pools.
- A sign shall be posted at each spray ground and be visible from any part of the spray ground that states, "CAUTION: WATER IS RECIRCULATED. DO NOT DRINK."



## Public Health

### Environmental Health Services

[www.SBCounty.gov](http://www.SBCounty.gov)

### RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT

FACILITY NAME HAMPTON INN & SUITES	DATE 4/14/2015
LOCATION 250 N 9TH ST, COLTON, CA 92324	INSPECTOR John Babalola

#### 36K434 Supervision - Lifeguards

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Re-attach the detached rope to the life ring.
	Not In Compliance	
	Violation Reference - HSC - 65521, 65537, 116033...	

**Violation Description:** Every pool shall be under the supervision of a person who is fully capable of, and shall assume responsibility for, compliance with all requirements relating to pool operation, maintenance and safety of bathers.

Persons providing aquatic instruction shall possess current certificates from an American Red Cross or YMCA of the U.S.A. lifeguard training program, or have equivalent qualifications, as determined by DEHS. In addition, these persons shall be certified in standard first aid and cardiopulmonary resuscitation (CPR).

Lifeguard service shall be provided for any public swimming pool that is of wholly artificial construction and for the use of which a direct fee is charged. The number of lifeguards shall be adequate to maintain continuous surveillance over the bathers. For all other public swimming pools, lifeguard service shall be provided or signs shall be erected clearly indicating that the service is not provided.

#### 36K444 Equipment - Recirculation Pump/Filter/Separation Tank

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> No flow direction labels observed in the equipment room. Provide labels.
	Not In Compliance	
	Violation Reference - HSC - 3120B, 3132B, 3141B	

**Violation Description:** Each pool shall be provided with a separate recirculation system designed for the continuous recirculation, filtration and disinfection of the pool water. The pumps, filters and all related parts of the pool water purification system shall be kept in operation whenever the pool is available for use. All parts of the pool and related pool facilities and equipment shall be maintained in good repair.

The backwash from a diatomaceous earth filter shall discharge into a separation tank. The wastewater from the separation tank shall discharge into a sanitary sewer or other disposal system acceptable to the local wastewater agency.

The direction of flow for the recirculation equipment shall be labeled clearly with directional symbols such as arrows on all piping in the equipment area.

#### 36K448 Equipment - Flow Meter

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Repair/replace the non-functional flow meter.
	Not In Compliance	
	Violation Reference - CCR - 3125B	

**Violation Description:** A flow meter shall be provided on each recirculation system accurate to within 10 percent of flow. Flowmeter shall be maintained in good repair, accurately displaying flowrate.

#### 36K458 Maintenance - Test Kit/Daily Records

<b>POINTS</b> <b>2</b>	Compliance Date: Not Specified	<b>Inspector Comments:</b> Maintain accurate daily records of pH and chlorine readings. No accurate daily records observed.
	Not In Compliance	
	Violation Reference - CCR - 65523, 65529	

**Violation Description:** Appropriate test kits for measuring the pH, concentration of the disinfectant, and, when used, concentration of cyanuric acid shall be provided at each pool. The test kit shall be capable of testing for free chlorine residual.

The operator of each pool open for use shall keep a daily record of information regarding operation, including readings of disinfectant residual, pH and maintenance procedures such as cleaning of filters and quantity of chemicals used.

#### Overall Inspection Comments

Observed pH = 7.6, chlorine = 0.0, cyanuric acid = 0.0, capacity = 20.

#### Signature(s) of Acknowledgement

NAME: jon patty  
TITLE: gm



**Public Health**  
**Environmental Health Services**

**RECREATIONAL HEALTH - OFFICIAL INSPECTION REPORT**

FACILITY NAME <b>HAMPTON INN &amp; SUITES</b>	DATE <b>4/14/2015</b>
LOCATION <b>250 N 9TH ST, COLTON, CA 92324</b>	INSPECTOR <b>John Babalola</b>

**Total # of Images: 0**